



CONNECT THE NO OR NC TERMINAL TO ANY UNUSED B1290 ALARM INPUT. FOR EXAMPLE, IF THE B1290 IS FAIL-SAFE WIRED (INPUTS ARE NORMALLY CLOSED TO GROUND), CONNECT THE NC TERMINAL TO THE B1290 INPUT AS ILLUSTRATED.

BE BARNETT ENGINEERING LTD.

CALGARY, ALBERTA CANADA

SIZE: **A**

DATE DRAWN: APRIL 17, 2015
 DESIGNED BY: SNB
 APPROVED BY:
 SCALE: 1:3

TITLE: **B 1294 WIRING DIAGRAM**

DWG NO.: **B 1294D005** REV: **1.1**

NOTES	REVISIONS		
	REV	DESCRIPTION	DATE
THE TERMINAL BLOCK ACCEPTS 12-26 AWG STRANDED WIRE			